

# Q & A

## Pre-Bid Conference: 1st Green Energy Auction Program in the Philippines

Date: 01 June 2022

9:00am-12NN via Zoom

### CAPACITY OFFER

NAME and AFFILIATION	QUESTIONS/COMMENTS	RESPONSES
Francis Sayre, Philnew Hydro/Philnewriver	in the "Submit Bids" form, what is the unit of "Offer Quantity"?	The Capacity Offer will be in megawatts (MW), but the price offer is in peso per kilowatt-hour (PhP/kwH)
Xavier Libardo, CSCI	Are we allowed to only offer a portion of the plant's registered capacity? For example, if the registered capacity is 100MW, can we only offer 50 MW?	Yes, the Electronic bidding platform will accept your offer. This will clarified further in the Bid Bulletin.
Henry Liqueste, Solarace 1 Energy	<p>May we clarify on the partial plant capacity offer. Based on the answer, a bidder may offer a portion of the plant capacity.</p> <p>However, according to the TOR, page 1 footnote, the capacity to be offered in the bid shall refer to the Pmax or the maximum stable load of the RE Facility. Also under GEAP Guidelines, Section 9.9 which requires offer of the entire capacity of the RE Facility.</p> <p>May we seek clarity on this. Thank you.</p>	This will be clarified in the Bid Bulletin. The Bidder may submit in its bid a Capacity Offer lower than the registered capacity under the RE Contract but full capacity of the entire power plant shall be offered.
Dakila Maniquis, COHECO	In section 7.3.2.2 of the TOR, marginal offers are allowed up to 20% of the maximum capacity being bid out. May we know the basis of the 20%? Since technically and commercially, it would be difficult to split the capacity of a plant, would it be better if the indivisibility principle is applied here similar to the policy for FIT1?	Reduction of capacity as an option refers to both capacity of the plant and the Capacity Offer. One revenue meter per plant rule will apply.

Joel Lubguban, Lumino Biomass	May we offer a different price for a percentage of our total capacity, then another price for the remaining percentage?	You can only offer a single bid for a single facility. Entire capacity (i.e. Pmax) of the plant shall be offered.
David Aboitiz, PVSPI	FIT rules state that no other off-taker is allowed. if one is now able to bid only partial capacity, contradicting TOR, it seems we can sell to other off-takers the remainder of the capacity that was not bid into geap	This will be clarified in the Bid Bulletin. The Bidder may submit in its bid a Capacity Offer lower than the registered capacity under the RE Contract but full capacity of the entire power plant shall be offered.
DSCC/CSCC, Roderick Fernandez	For a biomass plant, which is seasonal and depends on the available fuel, what will happen if the plant can only deliver a portion of the bid capacity?	The plant will be paid based on the actual generation output. ERC Rules will be applied for any plant outages.
SOLARACE1 Henry Liquete	Just to confirm, is it right to assume that the IT presenter was referring to the capacity as reflected in the Affidavit of Undertaking to Deliver Offered Capacity which the bidder can no longer amend, and not on the Registered Capacity in the Registration Form.	This will be clarified in the Bid Bulletin.
David Aboitiz - PVSPI	can we please seek confirmation from ERC because COC and FIT Rules are contradicting the partial capacity. Additionally, I don't believe ERC has historically allowed a single plant to have two meters	We don't allow partial Capacity Offer. The Bidder may submit in its bid a Capacity Offer lower than the registered capacity under the RE Contract but full capacity of the entire power plant shall be offered. This will be clarified in the Bid bulletin.
SCBP, NNBP - Arthur Aguilar	For the capacity to be offered, may we confirm if it is gross capacity or net export capacity for a biomass plant?	Net export capacity for all RE plants.
SCBP, NNBP - Arthur Aguilar	To confirm, we will no longer be required to indicate the indicative energy per year (MWh) and indicative plant factor (%) in the bid, as compared to Annex D4 Bid Form?	Bid Data Form will be revised (part of the Bid Bulletin).
Joel Lubguban, Lumino Biomass	Is the offered capacity is the average capacity for a year?	The Capacity Offer should be the Pmax and not the average capacity per year
Joel Lubguban, Lumino Biomass	Follow-up question, since we will be offering Pmax instead of average Power, what will happen during yearly shutdown that we cannot supply Power?	No generation, no payment
AREC - Christine Gale Paras	If we are allowed to offer partial capacities, will this not be inconsistent with the GEAP guidelines (Section 9.9)?	We don't allow partial Capacity Offer. The Bidder may submit in its bid a Capacity Offer lower than the registered capacity under the RE Contract but full capacity of the entire power plant shall be offered. This will be clarified in the Bid bulletin.

	In the TOR, the Offered Capacity should be the Pmax of the RE facility, which means it is for the full capacity. Will the TOR be changed?	No changes, this will be further clarified in the Bid Bulletin.
SOLARACE1 - Henry Liquete	To clarify, a bidder should offer the entire capacity of the Plant but not necessarily the entire capacity under the Service Contract.	yes! :)
	Is the following statement correct: Bidders should offer the ENTIRE capacity of the PLANT but not necessarily the ENTIRE capacity as reflected in the Service Contract or Operating Contract.  (Assuming there is capacity indicated in the Service or Operating Contract.)	yes again :)
Deiter Hoff P Arellano, Green Acres Renewable Energy Corporation	May I clarify on the capacity to be offered, If our service contract is at 12MW and I want to offer the whole plant? Do I have to offer 12MW or just the 10.8MW (net of our in house load)?	offered capacity should be the Net export capacity (based on test and commissioning)
SCBP, NNBP Arthur Aguilar	Can a biomass plant bid for partial of its max capacity?	No, one meter per plant rule will apply.
Philnew Hydro / Philnewriver - Francis Sayre	For NGCP connections, what would be possible issues with bi directional meters?	None.
	In TOR: 1.Are you going to require 2 meters for the winning bidder in marginal offer in the event that the winning bidder opts to agree to a reduced capacity?	Reduction of capacity as an option refers to both capacity of the plant and the Capacity Offer. One revenue meter per plant rule will apply.